



FAQ Number: 1288

Date Published: December 14, 2007 **Last Updated:** December 14, 2007

Question: How does a facility count the amount of release-flammable mixture with an NFPA rating of 4 if it is stored in either below or above ground tank(s)?

Answer: If a release-flammable chemical of interest is present in a mixture in a concentration equal to or greater than one percent (1%) by weight of the mixture, and the mixture has an NFPA flammability hazard rating of 4, the facility counts the entire weight of the mixture toward the STQ. If a release-flammable chemical of interest is present in a mixture, and the concentration of the chemical is less than one percent (1%) by weight, the facility need not count the mixture in determining whether the facility possesses the STQ.